

JI Project Utilization of APG at the Sredne-Khulymensk Oil Field
4th Monitoring Report

The chief engineer
JSC "RITEK"



/A.A. Maslanov/

"03" — 12 2012

JOINT IMPLEMENTATION PROJECT

4th MONITORING REPORT

Name of the Project:

**"Utilization of Associated Petroleum Gas
(APG) at the Sredne-Khulymensk Oil Field,
Western Siberia, Russia"**

Monitoring period: 1 January 2012 to 31 October 2012

Version 2.eng
23 November, 2012

4th Monitoring report:

Prepared by chief of department of an oil and gas recovery JSC "RITEK" –

A.O. Kulakov

Checked by:

The head of department of an oil and gas recovery JSC "RITEK" –

S.V. Shishkin

Internal audit was executed by head of department of corporate supervision JSC "RITEK"

A.V. Kotov

Moscow, 2012

**JI Project Utilization of APG at the Sredne-Khulymk Oil Field
4th Monitoring Report**

Table of contents:

Introduction		3
1. General project activity information		3
1.1.	Title of the project activity	3
1.2.	Short description of the project	3
1.3.	General scheme of the Project	6
1.4.	Monitoring period	6
1.5.	Implementation of the project	6
1.6.	JI Project and Monitoring report designers	6
2. Monitoring activities implemented		7
2.1.	Description of monitoring plan chosen	7
2.2.	Monitoring of environmental impacts of the project	7
2.3.	Deviation from the Monitoring Plan	8
2.4.	Data collection	9
2.4.1.	Algorithm of data collection	9
2.4.2.	Fixed values	9
2.4.3.	Data for calculation	10
2.4.4.	Using the IT technology at the data collection	10
2.4.5.	Description of formulae used to estimate project emissions	14
2.4.6.	Description of formulae used to estimate baseline emissions	15
2.4.7.	Treatment of leakage in the monitoring plan	20
2.4.8.	Description of formulae used to estimate emission reductions for the project	20

Annex №1: “Data for calculation”– 4 pages;

Annex №2: “Calculations” – 2 pages.

Annex №3: “Internal order about appointment of responsible persons in directions № 1986 from 28.12.2007” – 2 pages.

Annex №4: “Internal order № 73 from 05 june 2009 with Plan of action” – 6 pages.

Annex №5: A letter form “EnergoPerspektiva Ltd” ext. № 1/17 from 24/04/2009 – 1 page.

Annex №6: List of measuring devices – 3 pages.

JI Project Utilization of APG at the Sredne-Khulymensk Oil Field 4th Monitoring Report

Introduction

The purpose of this monitoring report is to calculate Greenhouse gas (GHG) emission reductions achieved by the Joint Implementation (JI) project Utilization of Associated petroleum gas (APG) at the Sredne-Khulymensk oil field, Western Siberia, Russia during the period from 1 January 2012 to 31 October 2012. 3rd monitoring report is developed by specialists of JI working group, confirmed by internal order of JSC RITEK #73 from 05 June 2009. All functions and responsibilities of the JI working group are stated in the "Plan of action of JSC RITEK JI working group" (Annex #4).

1. General project activity information

1.1. Title of the project activity

"Utilization of Associated petroleum gas (APG) at the Sredne-Khulymensk oil field, Western Siberia, Russia".

1.2. Short description of the project

The aim of the Project is utilization of associated petroleum gas on two modern power stations (Figure 1) with gas piston power generation units Cummins QSV 91G with the total installed capacity 15 MW located on Sredne-Khulymensk oil field (owner - JSC "RITEK"), Nadym district of Yamal-Nenets Okrug, Tumen region, Russian Federation (Figure 2) oil field with the purpose to supply electric energy for own needs of the oil field.

Figure 1. Project Gas Power Plant (GPP).




Figure 2. The location of Project.



The main components of the GPP are:

- QSV 91G Cummins gas-reciprocating engines produced by *JSC Zvezda Energetika* (fig.3);
- Stamford HV824C;
- Fuel gas supply system.

Jl Project Utilization of APG at the Sredne-Khulymensk Oil Field 4th Monitoring Report

Ten -18 cylinders, four stroke, high speed gas engines with electric spark ignition have been chosen, in part, because of their tolerance for lower quality APG-fuel and because of low pollutant emissions in the exhaust gas. The fuel gas supply system of the GPP, including gas pipelines (isolated for leakage minimization) and the APG treatment plant, is designed to support normal operation of the power generating units using APG. Each unit is equipped with a device that switches off fuel supply sources in emergency cases. The fuel gas flow rate at 100% load is 293 nm³/MW per hour. The fuel gas (APG) is taken from the gas pipeline of the APG treatment plant into the engine's gas mixer where air is added. The mix is then transported by pipe into the turbo-blower. Then, the compressed gas-air mixture goes through the cooler into the fuel suction line that distributes the mixture among the engine's cylinders. Design pressure at the fuel supply inlet is 3.5 Bars with temperatures from 10 to 20 degrees Celsius. The fuel used at the GPP is APG that is separated at the Sredne-Khulymensk booster pumping station. Minimal CH₄ index without decreasing power is 52 %. APG after separation is divided in two flows with one part directed to the GPP and the other flared at the existing stack of the booster pumping station.

Before use in gas-engines, APG must be processed at the treatment plant by:

- □Drying from dropping liquids while being heated up from +10 to +20°C,
- □Reducing pressure from 0,5 MPa to 0,35-0,4 MPa,
- □Gas filtration.

No incremental electric use is needed for gas treatment and transport due to the Project. The pressure at which gas comes into the APG treatment plant is sufficient to push it through the system. Heating of the gas is fully covered through use of waste heat from the gas engines.




Figure 3. Block of QSV 91G Cummins

Electrical Interconnection Systems

The GPP includes the following electrical equipment:

- 10 generators;

Jl Project Utilization of APG at the Sredne-Khulymensk Oil Field 4th Monitoring Report

- 6 & 0,4 kV gears;
- 0,4 kV transformers;
- in-house transformer substation with 0.4 kV distributor switch gear (for self consumption).

Delivery of the electricity to power consumers is provided from transforming station, voltage 6 kV. Total annual consumption from the given substation is estimated as 64,2 GWh/year. Own power consumption of the stations is approximately 2 GWh/year. Delivery of the electric power is carried out by 6 kV cables to the related transformers and facilities. In case of emergency switch-off of a gas supply system, or in other cases of absence of gas in APG processing facilities the power plants use emergency diesel fuel. Transition to emergency operation of work on GPP occurs in case of critical pressure drop in the gas pipeline. In case of GPP transition to work the emergency diesel fuel the emissions are calculated according to the actual expense of fuel and nameplate data on received emissions.

Electric power delivery in external grids, and also stabilization of voltage due to interconnection to high-voltage transformers in foreseeable prospect is impossible, because of very high expenses (exceeding cost of the power station), and difficult procedure of the coordination of generating object interconnection with external networks.

In the absence of the Project, the whole volume of the utilized APG would be flared (19,4 mln. Nm³ per year, Figure 4) and electric energy would be produced by firing oil at wagon-type power units PE-6M (39455 tones per year, Figure 5).

Figure 4. Associated petroleum gas flaring at Sredne-Khulymensk oil field.





Figure 5. Wagon-type power units PE-6M.




The termination of oil firing and utilization of APG will result in the GHG emissions reduction during the crediting period in volume of 105223 tones of CO₂-equivalent per year.

Actual investment in the Project amounted 15 mln euros.

JI Project Utilization of APG at the Sredne-Khulymensk Oil Field 4th Monitoring Report

1.3. General scheme of the Project.



1.4. Monitoring period

1 January 2012 – 31 October 2012

1.5. Implementation of the project

Table 1. Main milestones in project implementation

Milestone	Date
<i>UNFCCC JI procedures:</i>	
Project Design Document submitted to Accredited Independent Entity	27 May 2009
Determination of Project Design Document by Accredited Independent Entity	02 September, 2009
Letter of Approval from the Ministry for Economic development of the Russian Federation as a legal and authorised representative of the Government of RF	30 July, 2010
Final determination of the JI project	11 August, 2010
<i>Construction and operation of gas power station</i>	
Gas power station starts operating	29 October 2005

1.6. JI Project and Monitoring report designers

JI Project Utilization of APG at the Sredne-Khulymensk Oil Field is developed by:

LLC «Международная Группа «Sigma»

Moscow, Russian Federation

Tel. +7 (495) 7753232

Fax +7 (495) 7753232

e-mail: sigma@effort.ru

Monitoring report prepared, checked and confirmed by:

JSC «Russian Innovative Fuel-Energy Company» (JSC «RITEK»)

The chief of department of oil and gas recovery – A.O. Kulakov

The head of department of oil and gas recovery – S.V. Shishkin

Chief engineer JSC RITEK – A.A. Maslanov

Address: Russian Federation, 628486, Tumensky region, Kogalym, Noyabrskaya str. 7

Tel: +7(495) 665-76-89

Fax: +7(495) 424-77-15

Email: info@ritek.ru

JI Project Utilization of APG at the Sredne-Khulymsk Oil Field 4th Monitoring Report

2. Monitoring activities implemented

2.1. Description of monitoring plan chosen

The Project will contribute to sustainable development of the host country by promoting the utilization of a wasted energy resource and will achieve two goals:

- Reducing CH₄ emissions due to more complete APG combustion in gas engines relative to APG flaring;
- Substitution of power generation from the power trains to power from GPP with more efficient engine and reduced GHG emissions.

At present, no approved CDM monitoring methodology that would allow estimating CH₄ emissions mitigation from APG flaring reduction projects is available. On the other hand, the “Methodology of calculation of emissions of hazardous substances into the atmosphere due to the flaring of the associated petroleum gas at flaring stacks” developed by the Saint-Petersburg Scientific Research Institute for Protection of Atmosphere of Rosgidromet, (Rosgidromet) endorsed by State Committee for Environmental Protection – GosKomEcologiya, is designed for practical usage when estimating such emissions during APG flaring. This methodology is widely used by Russian oil and gas sector in calculations of hazardous atmospheric emissions. Therefore, modalities relating to CH₄ emission reductions estimation contained in the Rosgidromet methodology are used in the monitoring plan of this Project.

Estimation of CO₂ reductions due to the displacement of electricity generation from the power trains uses the elements of the Approved CDM Methodology - AM0009.

2.2. Monitoring of environmental impacts of the project.

According to the Order of the State Committee of the Russian Federation for Environmental protection as of 15.05.2000 # 372 “On the approval of the regulations on the assessment of the impact of the planned economic and other activity on the environment of the Russian Federation” the project developers must include in the project documentation the clause on assessment of environmental impact.

On assignment with *RITEK*, a scientific research institute “GiproTyumenneftegas”, has elaborated the environmental impact assessment (EIA), which consists of the following chapters:

- general part;
- physical-geographical characteristics of the Project site;
- characteristics of the Project GPP as a polluting source;
- water disposal and water usage;
- waste management;
- impact on atmospheric air;

JI Project Utilization of APG at the Sredne-Khulymensk Oil Field 4th Monitoring Report

- protection and sound management of land;
- scope of environmental protection works;

The environmental impact assessment (EIA) documentation with regard to this Project has undergone public environmental examination. The YaNAO Environment Protection Office (Nadym district) has issued a conclusion stating that the Sredne-Khulymensk GPP complies with the requirements of the environmental legislation, normative and technical design documentation.

A four level system for the monitoring of environmental impacts has been established at the GPP. This system allows monitoring, reporting and controlling of the maximum concentrations of the hazardous substances emissions such as CH₄, NO_x, and CO:

1. First, the gas contamination sensors that monitor CH₄ concentrations relative to maximum permissible emissions (MPE) limits are installed at the APG treatment plant and at condensate collection tanks.

2. Second, the generating units at the power hall are equipped with the *LENOX* controlling system, which automatically monitors CH₄ concentrations in the engines.

3. Third, the mobile mechanized plant, *TESTO*, monitors concentration of the hazardous waste in the exhaust gases at any desired measuring point (engine, power hall, etc). The emissions measurement may be taken in any required place. Once the data is measured, the shift operator inputs it in his log book.

4. Fourth, the shift operator is periodically on a beat monitoring the situation with gas emissions.

In case of exceeding the established MPE maximum limits, the signals from sensors will come in GPP's automated control system (ACS) that will adjust working parameters of the equipment to an optimized safe operation level.

In frameworks of National Environmental Regulation of host party – maximum permitted emissions (MPE) determined according to GOST 17.2.3.02-78 (regulation standards of harmful substance's emissions for Industry). GOST's using during estimation of environmental impact in frames of project documentation, simultaneously with established by Ministry of Health USSR in 1978 maximum permitted concentrations (MPC).

2.3. Deviation from the Monitoring Plan.

2.3.1. Monitoring plan, stated in section D PDD "Utilization of Associated petroleum gas (APG) at the Sredne-Khulymensk oil field", doesn't contain the coefficient, considering own needs of PE-6M.

The electricity supplied by GPP to the consumers at Sredne-Khulymensk oilfield in period of 2012 is 36 730,900 MWh. Accordingly to annex № 1, own needs of GPP in the period of 2012 year have made 2 131,240 MWh, or 5,48% from the total amount of produced energy on GPP – 38 862,140 MWh. Own needs for power trains PE-6M, which includes a power consumption on heating of oil on oil treatment

JI Project Utilization of APG at the Sredne-Khulymensk Oil Field 4th Monitoring Report

object and maintenance of necessary temperature in diesel engines for instant start for reserve, makes 7,40% (data from MR 2010).


Accordingly for delivery of similar quantity of the electricity by power trains to the consumers of Sredne-Khulymensk oilfield (36 730,900 MWh) it is necessary to develop on 7,40% more energy: $36\,730,900 \cdot (100 + 7,40) / 100 = 39\,448,987$ MWh. This figure will be used at calculation of emissions from power trains in table 8.

2.3.2. Parameter σ_{CH4} (total hydrocarbons in CH₄ equivalent) was used for calculation for ERU's in PDD table 11, BE3. This parameter was calculated by means of APG, including the whole number gas hydrocarbons (from methane to octane). Using the sum of hydrocarbons gases equivalent isn't correct, because only methane is GHG. The equation was corrected with adjusted for methane in MR. Final calculation of ERU's based on corrected equation.

2.3.3. Accordingly to the Volume 1, Chapter 7, box 7.2 page 7.6 "2006 IPCC Guidelines for National Greenhouse Gas Inventories" Calculating CO₂ inputs to the atmosphere from emissions of carbon-containing compounds (carbon monoxide CO) emissions will eventually be oxidised to CO₂ in the atmosphere. These CO₂ inputs could be included in national inventories. They can be calculated from emissions of CO. Thus, this specification to be reflected in calculation in equation BE4 positions 6 and 10. Value of positions 6 and 10 goes to zero. Final calculation of ERU's based on corrected BE4 equation.

2.4. Data collection

2.4.1. Algorithm of data collection



2.4.2. Fixed values

Table 1.

Parameter	Default value	Description
EF _{cm}	596,4 grUF/kWh	Emission factor for power production at wagon-type power units PE-6M

Factor of unified fuel equivalent use for generation (Tuf/MWh) was taken into account as stable parameters within due to 5 years of operating the powertrains. For monitoring plan it was considered appropriate to use determined by auditor ("EnergoPerspektiva" Ltd.) data from well Group #1 (TPP "RITEKNadymneft"), exploited powertrains until GPP commissioning. The average consumption in 2006

JI Project Utilization of APG at the Sredne-Khulymensk Oil Field 4th Monitoring Report

was 596,4 grUF/kWh in accordance with official report from 18.01.2007, Contract #17/23 (Annex №5). Modification (theoretical) of quality of fuel, that can additionally reduce emissions, compensates by decreasing efficiency of consuming equipment due to their physical amortization, and accordingly growth of energy consumption (and fuel reduction in frameworks of project line).

2.4.3. Data for calculation

All measurements are executed automatically by means of the checked devices according to the Monitoring plan, stated in section D PDD “Utilization of Associated petroleum gas (APG) at the Sredne-Khulymensk oil field”.

Collecting and archiving of all measurements are executed by qualified personal of TPP “RITEKNadymneft” according to the internal order about appointment of responsible persons in directions (Annex №3).

All data is presented in an electronic and paper kind on object GPP Sredne-Khulymensk oilfield, and also in office building TPP “RITEKNadymneft” (Nadym).

2.4.4. Using the IT technology at the data collection

At the GPP level, the shift operators will be responsible, on day-to-day basis for monitoring the variables, including taking the readings from electricity meters, APG flow meters and the fuel tank contents and deliveries. The monitoring and reporting of most of these data (volume, capacity and electricity flows) has been already adopted under the routine operation regime of the GPP.

On the basis of the received daily data from the electricity meters of GPP operators enters figures to the spreadsheets in the Microsoft Excel program. The operator will transfer them via the internet to the Energy Department in the office bldg TPP “RITEKNadymneft”.

At the TPP “RITEKNadymneft” the head of the energy department checks and processes the daily data received from operator of GPP of Sredne-Khulymensk oilfield to the monthly and annual reports. These reports are:

- saved on the computers at the Energy department;
- printed and archived in paper kind at the Energy department and GPP of Sredne-Khulymensk oilfield;
- sent by internal e-mail with the protected channel to the head office of JSC RITEK in the Energy Department.

At the head office of JSC RITEK all received reports take place in limited access at the public directory. All interested persons have access, protected by password, for reports to check and verify it. Verified reports will be saved at the server of JSC RITEK until 2015 year.

JI Project Utilization of APG at the Sredne-Khulymensk Oil Field 4th Monitoring Report

After the internal verification of received reports, annual data is entered into the program for calculation ERU's. This program is developed on base of Monitoring plan (PDD section D). Microsoft Excel program will make the necessary calculations with the use of formulas.

Table 2. Information on key parameter monitored

Data/Parameter	Gen
Data unit	MWh
Description	Electricity supply to consumers at Sredne-Khulymensk oil-field on voltage 6 kV, and electricity supplied for self consumption 0,4 kV.
Time of determination/monitoring	Monthly
Source of data (to be) used	Electric meters «СЭТ 4ТМ»
Value of data applied (for ex. ante calculations/determination)	MWh, shown below in Table 3
Justification of the choice of data or description of the measurement methods and procedures to be applied	Electric meters are installed at the 6 kV (0,4 kV) in-door switch gears, data will be archived electronically and in monitoring workbook.
QA/QC procedures (to be) applied	QA: measurements from the electricity meters is screened on monitors at the operator's desk; readings are taken by the trained staff according to the requirements of the technical specifications; QC: periodic calibration by the regional representatives of the State Office for Metrology and Standardization
Any comment	-
Data/Parameter	Vi
Data unit	%
Description	Composition of recovered gas measured at point M2, after pretreatment, during the period y
Time of determination/monitoring	Two times a year (winter, summer season) (table 4 below)
Source of data (to be) used	Measurement providing by authorized company with the license for the given kind of activity or at the own JSC "RITEK" chemical laboratory at Sergino oilfield
Value of data applied (for ex. ante calculations/determination)	Vi shown below in Table 5
Justification of the choice of data or description of the measurement methods and procedures to be applied	By authorized company or at the own chemical laboratory on its chromatograph («Кристалл-5000», JSC "Chromatech") at the junction point and at exit from KONGV pre-treatment two-times a year figures (winter and summer season). The structure of APG will be used for calculation, that will allow to receive the most conservative result.
QA/QC procedures (to be) applied	QA: measurements are taken by the trained staff according to the requirements of the technical specifications; QC: periodic calibration by the regional representatives of State Office for Metrology and Standardization
Any comment	M APG and density calculating on the base of available APG composition.
Data/Parameter	$V_{F,y}$
Data unit	Nm ³
Description	Volume of APG consumption for power generation at points M1 and M2, during the period y
Time of determination/monitoring	Monthly (table 5 below)
Source of data (to be) used	Flow-meters - "ИРВИС-РС4», DYMETIC 9421
Value of data applied (for ex. ante calculations/determination)	Nm ³ , shown below in Table 6

**JI Project Utilization of APG at the Sredne-Khulymensk Oil Field
4th Monitoring Report**

Justification of the choice of data or description of the measurement methods and procedures to be applied	Measurements effectively show volume of APG that would be flared in frames of baseline. It is typical procedure using for settlements between Project's owner and GPP's exploiting company (Zvezda Energetika).
QA/QC procedures (to be) applied	Volume of APG will be completely metered with regular calibration of metering equipment. The measured volume should be converted to the volume at normal temperature and pressure using the temperature and pressure at the time to measurement.
Any comment	-

Table 3. Data on electricity supplied by GPP to the consumers at Sredne-Khulymensk oil-field in period of 2012:

Month	Electricity supply to consumers at Sredne-Khulymensk oil-field, MWh
January	4 195,960
February	3 954,240
March	4 120,890
April	3 826,540
May	3 910,280
June	3 035,750
July	3 091,620
August	3 266,210
September	3 289,890
October	4 039,520
Total over the monitoring period	36 730,900

* - The quantity of the electric power developed on GPP of the Sredne-Khulymensk oilfield at period of 2012 differs from the declared annual development of the electric power 66,2 GWh because of reduction of loadings from power consumers in connection with falling of level of annual oil recovery.

Accordingly, the quantity of the electric power spent at period of 2012 to the power consumers of the oilfield, was reduced.

Table 4. The componental structure of APG, used for electricity development at GPP Sredne-Khulymensk:

Component	Winter season measurement (№ 135 from 07.04.12 by KogalymNIPIneft)	Summer season measurement (№ 331 from 15.08.12 by KogalymNIPIneft)	Value used in calculation*
CH ₄	80,353	75,695	75,695
C ₂ H ₆	4,092	4,596	4,596
C ₃ H ₈	6,929	8,557	8,557
nC ₄ H ₁₀	2,565	3,715	3,715

**JI Project Utilization of APG at the Sredne-Khulymsk Oil Field
4th Monitoring Report**

iC ₄ H ₁₀	1,666	2,270	2,270
nC ₅ H ₁₂	0,501	0,960	0,960
iC ₅ H ₁₂	0,525	0,926	0,926
C ₆ H ₁₄	0,271	0,589	0,589
C ₇ H ₁₆	0,162	0,148	0,148
C ₈ H ₁₈	0,013	0,025	0,025
N ₂	1,810	1,115	1,115
CO ₂	1,113	1,404	1,404
Calculation of GHG emissions	53 190	52 526	52 526

* - The calculation with the summer season measurement (№ 331 from 15.08.12) allow to receive the result of GHG emissions in the amount 52 526 tonnes of CO₂-equivallent.

The calculation with the summer winter measurement (№ 135 from 07.04.12) allow to receive the result of GHG emissions in the amount 53 190 tonnes of CO₂-equivallent.

All calculations have been executed and given to the verifier.

Difference between two calculations with summer and winter season measurement makes 664 tonnes CO₂-e or 1,25%. For the present Monitoring Report we use most conservative result.

Accordingly to the PDD measurements of componental structure of APG should be executed 2 times a year (winter and summer season) by the means of authorized company. In 2012 year measurements have been executed two-times a year by the means of "KogalymNIPIneft".

Table 5. Volume of APG consumption for power generation, after pretreatment, during the MP.

Month	Volume of APG consumption for power generation, mln. Nm³
January	1,192
February	1,118
March	1,170
April	1,074
May	1,068
June	0,853
July	0,842
August	0,892
September	0,892
October	1,080
Total over the monitoring period	10,181 **

JI Project Utilization of APG at the Sredne-Khulymensk Oil Field 4th Monitoring Report

** The volume of APG declared under the Project "Utilization of APG at the Sredne-Khulymensk oilfield" makes 19,4 million nm³/year. This figure is received with the fuel gas flow rate at 100% load.

The actual volume of APG consumption for power generation makes 10 180 952 nm³/period of 2012 year. It is connected with actual loading of GPP. Level of loading of GPP decreased within 2012 year in connection with the reduction of a level of the electric power productions with falling of oil recovery.

2.4.5. Description of formulae used to estimate project emissions

The equations used to calculate Project emissions are summarized in Table 6 below.

The project uses the approach from the previously approved CDM methodology AM0009 version 3 and assumes full oxidization.

$$PE_{y} = (V_{y} * P_{y}) * W_{carbon,A,y} * 44/12 \quad (PE1)$$

where:

PE_{y} - the baseline emissions during the period y in tons of CO₂ equivalents.

V_{y} - volume of gas recovered from the oil field during the period y, explicated in (000) nm³.

P_{y} - density of APG, kg/nm³ (c.2 BE1).

$W_{carbon,A,y}$ - the average content of carbon in the gas recovered during the period y.

The carbon content in the gas $W_{carbon,A,y}$ is determined from Table 7, 1.

Table 6: Project emissions calculation equations

	1	2 from 9, BE1	3	4	5	6=1*2*3*4/5
PE1	Mass amount of APG consumption	Carbon mass fraction in APG		Molecular mass of CO ₂	Molecular mass of C	Total CO ₂ emissions project
	M_{APG}	$\sigma_{c,APG}$	scalar	μ_{CO_2}	μ_C	$ECO_2_{combustion\ project}$
unit	t	% mass		kgCO ₂ /mole	Kg C/kg mole	tCO ₂ e
	10 797,281	75,911	0,01	44,011	12,011	30 033

Thus, total project emissions 30 033 tCO₂e/period of 2012 year.

As explained in PDD Section B.2, emissions based on leakages and/or accidents are likely to be greater in the baseline delivery of APG to the flare than they will be in the operation of the new GPP. Therefore, potential leaks and accident emissions in the Project scenario have been ignored to assure that the emission reduction estimates are based on conservative assumptions.

2.4.6. Description of formulae used to estimate baseline

Baseline emissions at the Sredne-Khulymensk flare are calculated using equations *BE2* through *BE6* below in combination with *BE1* as shown in Table 7.

Columns (6) in equation *BE4* and column (1) in equation *BE3* are parameters that are specified in the Rosgidromet methodology for calculating emissions from flaring of APG in Russia. The factors shown assume that the Sredne-Khulymensk flare will continue to operate in black-firing mode. The

**JI Project Utilization of APG at the Sredne-Khulymk Oil Field
4th Monitoring Report**

monitoring plan addresses the photo evidence that will support this assumption going forward. The key input parameters for future years will be the volume of APG used by the GPP (column (1) in equation BE5, the density of that APG and the volumetric composition of the APG.

**J1 Project Utilization of APG at the Sredne-Khulymysk Oil Field
4th Monitoring Report**

Table 7: Equations for local baseline emissions at the APG flare

1. Calculation of mass fraction of APG components

BE1	index	1	2	3	4	5	6	7	8=1 ⁵ /100	9=6 ⁷	10=7 ³ *3/miCH4	11	12=11 ⁷
		<i>V_i</i> Volume fraction, weighted average of monitored	<i>P_y</i> Density of hydrocarbons and elements	<i>m_i</i> Molecular mass of components	<i>μ_i</i> Molecular mass of i-component in APG	<i>k_i</i> Adiabatic index of i-component of APG	<i>oc-i</i> Mass content of carbon of i-component in APG	<i>σ_i</i> Mass ratio	<i>k</i> APG Adiabatic index of APG	<i>σ_C</i> APG Mass fraction of Carbon in APG	<i>σ</i> CH4 Hydrocarbons in CH4 equivalent	<i>σ_{H-1}</i> Mass content of Hydrogen of i-component in APG	<i>σ_H</i> APG Mass fraction of Hydrogen in APG
	CH ₄	75,695	0,716	16,043	12,144	1,31	74,87	0,5110	0,9916	38,2615	0,511039	25,13	12,8424
	C ₂ H ₆	4,596	1,342	30,07	1,382	1,21	79,98	0,0582	0,0556	4,6514	0,109007	20,02	1,1643
	C ₃ H ₈	8,557	1,969	44,097	3,773	1,13	81,71	0,1589	0,0967	12,9812	0,436681	18,29	2,9057
	nC ₄ H ₁₀	3,715	2,595	58,124	2,159	1,1	82,66	0,0909	0,0409	7,5139	0,329337	17,34	1,5762
	iC ₄ H ₁₀	2,270	2,595	58,124	1,319	1,1	82,66	0,0555	0,0250	4,5913	0,201237	17,34	0,9631
	nC ₅ H ₁₂	0,960	3,221	72,151	0,693	1,08	83,24	0,0292	0,0104	2,4270	0,131127	16,76	0,4887
	iC ₅ H ₁₂	0,926	3,221	72,151	0,668	1,08	83,24	0,0281	0,0100	2,3410	0,126483	16,76	0,4714
	C ₆ H ₁₄	0,589	3,842	86,066	0,507	1,07	83,73	0,0213	0,0063	1,7866	0,114470	16,27	0,3472
	C ₇ H ₁₆	0,148	4,468	100,08	0,148	1,06	84,01	0,0062	0,0016	0,5238	0,038897	15,99	0,0997
	C ₈ H ₁₈	0,025	6,230	114,23	0,029	1,05	84,21	0,0015	0,0003	0,1237	0,010457	15,79	0,0232
	CO ₂	1,404	1,965	44,011	0,618	1,3	27,29	0,0260	0,0183	0,7099	2,008735	0	0,0000
	N ₂	1,115	1,251	28,016	0,312	1,4			0,0156			0	0,0000
	Total	100,000			23,753			0,9868	1,2721	75,9114			20,8819
			1,0605										

**Jl Project Utilization of APG at the Sredne-Khulymensk Oil Field
4th Monitoring Report**

2. Quantity of carbon atoms in molecular formula of APG

BE2	1 from 9, BE1	2 from 4, BE1	3	4	5=(1*3/4)*2
	Mass fraction of Carbon in APG	Molecular mass of APG		Molecular mass of carbon	Quan. of carbon atoms in molecular APG
units	σC_{APG}	μAPG	Scalar	μC	Kc
	% mass	kg/mole	0,01	kg/mole	carbon atoms
	75,9114	23,753	0,01	12,0110	1,501

3. CH₄ emission factor for APG flaring

BE3	1	2 from L17, BE1	3=1*2	4 from L6, BE1	5=1*4
	Under firing coefficient	σCH_4 equivalent	e CH ₄ baseline	$\sigma GHG CH_4$	GHG CH ₄ baseline
units	scalar	Total hydrocarbons in CH ₄ equivalent	CH ₄ equivalent emission factor_baseline	Molar ratio of CH ₄ in APG	Mass fraction of CH ₄
	0,035	% mass	Kg CH ₄ /kg APG	% mass	Kg CH ₄ /kg APG
		2,009	0,0703	0,511	0,0179

4. CO₂ emission factor for APG flaring

BE4	1	2 from 5, BE2	3 from 4, BE1	4 from 3, BE3	5	6	7	8=2/3	9=4/5	10=6/7	11=1*(8-9-10)
	Molecular mass of CO ₂	Quan. of carbon atoms in molecular APG	Molecular mass of APG	CH ₄ emission factor_baseline	Molecular mass of CO ₂	CO emission factor_baseline (black firing)	Molecular mass of CO	C emission factor_baseline	Molecular mass of CH ₄	Molecular mass of CO in APG	CO ₂ emission factor
Units	μCO_2	Kc	μAPG	e CH ₄ baseline	μCH_4	e CO baseline	μCO	e C_baseline	Kg CH ₄ /mole APG	Kg CH ₄ / mole APG	e CO ₂
	44,011	Carbon atoms	kg APG/mole	Kg CH ₄ /kg APG	kg CH ₄ /kg mole	Kg CO/kg APG	kgCO ₂ /mole				Kg CO ₂ /kg APG
		1,501	23,753	0,0703	16,043	0	28	0,0632	0,0044	0,0000	2,5887

Jl Project Utilization of APG at the Sredne-Khulymsk Oil Field
4th Monitoring Report

5. Mass amount of APG flared

BE5	1	2 form 2, BE1	3=1*2
	Annual volumetric flow of APG to be flared	Density of APG	Mass amount of APG flared
units	V_{APG}	ρ_{APG}	M_{APG}
	ncm (1000)	kg/nCM	t
	10 180,952	1,061	10 797,281

6. Total emissions from APG flare

BE6	1 from 3, BE5	2 from 11, BE4	3 from 5, BE3	4	5=1*2	6=1*3*4	7=5+6
	Mass amount of APG flared	CO2 emission factor_baseline	CH4 emission factor_baseline	CH4 global warming potential	CO2 emissions from complete burning	Total CH4 emissions in terms of tCO2e	Total CO2 emissions from APG flaring
Units	M_{APG}	$e_{CO2_baseline}$	$e_{CH4_baseline}$	GWP CH4	$E_{CO2_complete_baseline}$	$E_{CH4_baseline}$	$E_{CO2_flaring_baseline}$
	t	Kg CO2/kg APG	Kg CH4/kg APG	scalar	tCO2e	tCO2	tCO2
	10 797,281	2,5887	0,0179	21	27 950,849	4 055,608	32 007

The second major component of baseline emissions is the GHG to be released by powertrains in course of generating power equal to the power amount to be generated by the GPP within the Project. Table 8 shows equation PE2, PE3 that used to calculate baseline emissions from powertrains.

Total power deliveries to consumers will be metered and confirmed by data from ACS, meter equipment reflecting actual load, forming current regime of GPP work. Algorithm of ACS management is:

Growth of loads (consumption) → decrease of voltage → additional (power) engines started → increasing generation → increasing gas consumption.

JI Project Utilization of APG at the Sredne-Khulymsk Oil Field 4th Monitoring Report

So in comparison with GPP working with external network, GPP on Sredne-Khulymsk oil field actual consumption and actual delivery have more objective data, suitable for monitoring plan. All losses in local grid will be calculated as the difference between power generated and derivative of installed equipment capacity and hours of operation.

The Table 8 combines local and power-trains fuel consumption and emissions to calculate the total annual *ex-ante* estimate of baseline emissions.

Table 8: Baseline powertrains emission equations electricity generation, and total baseline emission

1. Electricity generation (GPP-1 and GPP-2)

	1	2	3	4	3=1*2
PE2	Electricity supplied by GPP to the consumers of oilfield	Coefficient of own needs of PE-6M	Electricity supplied on PE-6 with own needs	Consumption tons equivalent fuel per MWh	Total fuel consumption
	<i>Elec_gen1</i> MWh	<i>Own_needs_coef</i>	<i>Elec_gen2</i> MWh	<i>EF_{CM}</i> tuf/MWh	<i>t_ufuel</i> t
Units	36 730,900	0,074	39 448,987	0,596	23 527,376

2. Baseline powertrains emission equations electricity generation

	1	2	3=1*2	4	5=3*4	6=5*44/12
PE3	Total fuel consumption	Energy per ton of unified fuel	Total energy consumption	Default carbon content	Total carbon content	Trains CO2 emission
	<i>t_ufuel</i> t	<i>Energy_coef</i> MJ/tuf	<i>total_energy</i> MJ	<i>carbon_factor</i> kg/GJ	<i>total_carbon</i> kg	<i>trains_CO2</i> tCO2
Units	23 527,376	29 300	689 352 105,321	20	13 787 042,106	50 553

1. For purposes of present sector of Monitoring Report emission factor CH₄ and N₂O was not defined due to it's extremely inferiority (< 1% from total emissions);

2. Default carbon content factor (rate for crude oil) was considered, as the most corresponding to specific of oil-field exploitation. (According to

Table 1-3 of 2006 IPCC Guidelines for National Greenhouse Gas Inventories Volume 2, "Energy", Chapter 1).

JI Project Utilization of APG at the Sredne-Khulymensk Oil Field 4th Monitoring Report

3. Total baseline emissions

	1	2	3=1+2
PE4	Total CO2 emissions from APG flaring	Trains CO2 emissions	Total baseline emissions
	<i>E CO2e flaring baseline</i>	<i>trains_CO2</i>	<i>ECO2e_total_baseline</i>
Units	tCO2	t	t
	32 007	50 553	82 560

2.4.7. Treatment of leakage in the monitoring plan:

No leakages were identified that correspond to net changes of emissions which occur outside the project boundary and are measurable and attributable to the Project activity. The emissions related to installing the new equipment will not be significant. Much greater emissions could be associated with delivery of gas to grid power plants situated in region, which does not occur in the Project that presumes local on-site power generation and consumption. Therefore, the exclusion of leakages from the Project will assure conservatism in the estimation of emission reductions within the Project.

2.4.8. Description of formulae used to estimate emission reductions for the project.

Ex ante estimates of the total annual emission reductions for the Project have been derived in equation *PE5* as a difference between the total baseline emissions estimated by equation *PE4* in Table 8 and total Project emissions estimated by equation *PE1* in Table 6.

Table 9: Annual emission reductions

	1 from 3, PE6	2 from 6, PE1	3=1-2
PE5	Total baseline emissions	Total CO2 emissions project	Total emissions reduction
	<i>ECO2e_total_baseline</i>	<i>ECO2_combustion project</i>	<i>ER CO2e_total</i>
Units	t	tCO2e	tCO2e
	82 560	30 033	52 527

Thus, the termination of oil firing and utilization of APG will result in the GHG emissions reduction during the monitoring period in volume of 52 527 tonnes of CO2-equivalent.